ER. PRADEEP KUMAR VARSHNEY
AMIE(CIVIL)
(Structure Engineer, Valuer, Estimator)
* Govt Approved Valuer No F-4895
* Income Tax Valuer No-V-01/2007-08
* Chartered Engineer No- 77496/3
* Approved From A.D.A.,Aligarh
* RVO Memb. NO.- IIV-RVF/OM/108/2020
* OBPAS ID No- AM0774963/26072018

ARCHINEER
HOME DESIGNER

Office cum Residence:-
99-F, Bank Colony
Premier Nagar,
Near Param Shakti Mandir,
Aligarh-202001
Mob: - 9837052118
E.Mail:- archineerhd@gmail.com

Panel Valuer of: *LICHFL *PNB *BPCL *ICICI * BANK OF BARODA *UJJIVAN *SBI

TO WHOM IT MAY IN CONCERN

Pursuant to the request from the Director Sri Mahak Singhal of Radiant Star English School run by Rama Educational Welfare Society, I inspected for checking the stability of structure of building as per N.B.C.-2005 (National Building Code).The Site is situated at Aligarh-Khair Road, Aligarh and Construction work of building was done in the year -2006-07. A.D.A. Sanctioned No- 815/15 (2004-05), Dated- 13-12-2005.

Covered area of construction at lower ground floor portion is 960.00 Sqm , Upper Ground floor Covered area is 2560.00 Sqm and first floor Covered area is 2560.00 Sqm. Total covered of all floors is 7680.00 Sqm. Plot area of this School building is 9103.15 Sqm. School campus is situated on 120'0" wide Aligarh-Khair Road.

In the specification of building it is a R.C.C. Framed Structure, with walls & foundations are in Brick work in cement mortar Flooring is in C.C. Floor /Kota Stone. Slabs are R.C.C. .

There are numbers of extinguishers for fire safety purpose. Two Hose reels are provided near stairs. Overhead water tank fire tank is also provided at terrace. Fire Safety aspects have been provided for fire prevention and life safety.

Pradeep Kumar Varshney
CHARTERED ENGINEER No. A.M.-77496/3
99-F Bank Colony, Aligarh

CamScanner

Proper Lighting, Daylight utilization, Ventilation is provided in this building. Water Supply, Sewage, Sanitary system (Including Solid Waste) is provided for Health precaution purpose. Rain water Harvesting System is also provided.

Therefore it is to Certify that the Structural and foundation design of Buildings of Radiant Star English School, satisfy requirements as stipulated in the relevant **INDIAN STANDARD CODES / NATIONAL BUILDING CODE-2005.**

Above Building safe from heavy rains& Earthquakes. In my Opinion the further life of building is approximately **Sixty Five Years.**

Date ;- 19-03-2025

Pradeep Kumar Varshney
CHARTERED ENGINEER No. A.M.-774596/3
29-F Bank Colony, Kanpur

Er PRADEEP KUMAR VARSHNEY

STRUCTURAL ENGINEER

CamScanner